

Memo

Carmichael



RECREATION AND
PARK DISTRICT

To: Advisory Board of Directors

From: Tarry Smith, District Administrator

Date: November 17, 2016

Subject: Approval of the Energy Efficiency Proposal from SMUD for the La Sierra Community Center.

Introduction/Background:

As part of our discussed mission for the efficient operations of the District, staff has been looking for ways to decrease costs of the District.

Staff contacted SMUD to do a no cost energy audit for the District. SMUD has presented their findings to staff for the La Sierra Community Center and requires a decision by the Advisory Board to accept or deny the quote (Attached A) and proposal. This quote is time sensitive as it involves SMUD contracting out the work and providing the materials; the current listed pricing and warranty offers are part of the attached quote and cannot be held indefinitely

Discussion:

Maintenance staff met with a SMUD representative at La Sierra to evaluate the entire site for energy efficiency. The study was narrowed down to efficiency that could be achieved by changing over to LED lighting as earlier upgrades have already been made to our operating system. A subsequent study is also going on at Carmichael Park and results will be forwarded in the near future.

SMUD has presented a proposal that calculates current possible energy savings by retrofitting the existing lighting with LED bulbs. This does not require the changing of existing ballasts.

The quoted energy savings by this change is significant. SMUD projects a savings of \$26,000 dollars in the first year and \$131,000 dollars over 5 years. The cost to accomplish these savings is a one-time amount of \$112,203.

According to SMUD this project would be eligible for the following rebates.

EA Grant - \$ 9,284
Rebates - \$28,142

After rebates the total cost of the project is (\$74,778). The project cost to the District is projected by SMUD to have a 2.8 year payback in energy savings. The District would not have to advance the whole payment and wait for reimbursement, the District would only pay the \$74,778, after the project is complete and the District is satisfied with the work.

Funding options for this project are varied as described in (Attachment B). There is a total of \$258,642 available for use on this project from allocated funds but not used as result of completed projects under budget, undesignated allocated projects funds and funds not yet spent for scheduled projects; all of which are outside of the District reserve. There is an additional \$19,395 dollars available in Park fees which are undesignated.

Recommendation:

Staff recommends that the Advisory Board of Directors of the Carmichael Recreation and Park District approve the proposed SMUD project, identify a funding source and authorize the District Administrator to execute the contract.



This program is brought to you by SMUD and implemented by Ecology Action

Complete Energy Solutions Energy Efficiency Proposal

La Sierra Community Center

Project Name:

La Sierra Community Center

Project Location:

5325 Engle Road
Citrus Heights, California 95608

Presented To:

Tarry Smith

Presented By:

Toni Renee Vierra
Mobile: (707) 373-0815

Email: trvierra@ecoact.org

For questions during your installation, please
contact your Installation Manager:

Stephen Hatcher


1111 Howe Ave Suite 520
Sacramento, CA 95825

Mobile: 916-425-6817

Email: shatcher@ecoact.org

Savings Summary

Total Installed Cost	\$112,203.91
EA Grant	\$9,284.54
Total Rebate**	\$28,141.06
Your Copay	\$74,778.31
Percent of Job Cost Covered	33%
Estimated Monthly Savings	\$2,180.94
Estimated 1st Year Savings*	\$26,171.17
Estimated 5 Year Savings*	\$130,855.85



Environmental Benefits

Estimated Annual Energy Savings	205,410.06 kWh
Estimated Power Savings	49.26 kW

By implementing the measures outlined in this proposal you will save enough energy to achieve one of the following:



Removal of 27.73 passenger vehicles from the road.



Addition of 301.95 acres of pine or fir trees (over a 10 year life span).

The project cost is based on current equipment prices and rebate levels and is valid for a period of 14 days from the date presented.

*Note - Savings are estimated using standard engineering calculations and are based on the hours of operation as described to the surveyor. Depending on actual usage as well as changes in your electric utility rate, your savings may be higher or lower. The savings indicated above are NOT guaranteed. Construction costs may vary slightly depending on fixture quantities and unforeseen conditions.

**Note - Based on DEER property type and measure savings values, This project is estimated to deliver 0.00 LkWh and 27.71 kW. The rebate offered for this project is calculated on the estimated lifetime kilowatt hours (LkWh) saved based on property type, measure savings values, and the estimated useful life of measures installed.

Below is a summary of work to be performed. The first table shows total costs for all work to be performed in this proposal. The second table shows a list of individual work orders referenced by this proposal. To authorize the job initial next to each work order in the section provided. Not initialing may delay when installation will commence.

Work Order Cost Breakdown Summary

Disposal	\$3,737.71
Material	\$71,807.18
Labor (weekdays Rate)	
Base Labor Cost	\$26,674.90
Access Difficulty Cost Adjustment	\$0.00
Ceiling Height Cost Adjustment	\$2,819.35
Labor Total	\$29,519.45
Other Fees (Permits, Inspections, Lifts, etc.)	\$2,526.68
Estimated Taxes	\$5,749.84
Total	\$112,203.91

Work Order List Summary

Work Order	Installed Cost	Rebate	EA Grant	Customer cost	Initials
La Sierra (Carmichael Parks & Rec) 2016-10-18 11:33:07	\$112,203.91	\$28,141.06	\$9,284.54	\$74,778.31	x



La Sierra Community Center
5325 Engle Road
Citrus Heights, California 95608

Customer Work Order Agreement

By signing this Customer Work Order Agreement ("Agreement"), Customer (the business entity listed above) agrees to the following:

Measures and Incentives:

I have reviewed the Energy Efficiency Upgrade Summary and Report ("Report") provided by the Complete Energy Solutions Program ("Complete Energy Solutions", "CES" or "Program"), a copy of which is attached to this Agreement. I agree that to the best of my knowledge the schedule of operations contained in the Report accurately describes the hours of operation at the facility listed above. I understand that the energy efficiency measures described in the Report represent an estimate of expected energy savings, and that Complete Energy Solutions does not guarantee a specific level of cost savings from the implementation of the proposed energy efficiency measures (collectively, the "Project").

Complete Energy Solutions is implementing the Project on the Customer's behalf. Incentives for energy savings are calculated using the appropriate baseline to exceed California Title 20 and Title 24 standards. New products ordered, purchased or installed prior to 6/1/16 or after 5/31/18 do not qualify for an incentive. Resale products, products leased, rebuilt, rented, received from warranty of insurance claims, exchanged, won as a prize or new parts installed in existing products do not qualify for Incentives. SMUD is not responsible for the economic and technical feasibility, operational capability, and reliability of the Project.

Program Dates:

To be eligible for incentives, all projects must be installed and completed before May 31, 2018. Funding of incentives is distributed on a first-come first-served basis. I have received information about other programs offering rebates or services for measures covered by the Complete Energy Solutions Program.

Project Commitment and Installation Completion Process:

I understand that I must have a signed Site Access Agreement on File to confirm Program Eligibility and a signed Customer Agreement to initiate installation. For each work order, I agree to have Complete Energy Solutions contact (a) participating contractor(s) ("Contractor") who will perform a walk-through inspection, review the scope of the Projects outlined in the Report, and schedule the Project installation at a time that is mutually agreeable to all parties. I understand that the total installed costs for the components of the Project are described in the attached listing of individual work orders. Costs for correcting electrical code violations are not included in the costs quoted above and are not covered by the Program. Any electrical code violations found during the Contractors' inspections or during installation will be cause for the Contractors to stop work on the affected item(s) until such violations are corrected. I understand that the contractor walk- through may result in a Change Order due to specification or electrical code violations and that I will be notified and approve of any cost adjustments before additional work is completed.

I will sign an agreement with each Contractor, which shall be solely between the Contractor and Customer, for the out-of-pocket portion of the Project costs. I understand that Complete Energy Solutions will provide a rebate, detailed in the work order listing, to offset the cost of the Project installations, and the rebate can be paid directly to the Contractors. I understand that I am responsible for paying the balance of the agreed-to contract price after rebate payment and that payment is due to the Contractor upon completion of the individual work order. By enrolling in the Program, I agree not to seek reimbursement from any other energy efficiency program for the same measures rebated under other programs. I understand that I am responsible for reimbursing the CES Program should I receive other incentive payments for the same installations. At the completion of the project, I agree to sign the Customer Acceptance/Project Completion Form presented by the contractor on Ecology Action's behalf.

The value of Incentives and direct installations is taxable. Implementer will report incentives and direct installations greater than \$600 to the IRS unless you are exempt. Please consult your tax advisor concerning the taxability of incentives. The Customer, not the implementer, is responsible for any taxes imposed as a result of your receipt of Incentives from this Program. Form 1099 will be issued for the Customer, regardless of who the payee is, because the Customer receives the benefits of the Incentives.

___ Initial here if you would like to direct the incentive payments to the Trade Contractor

Customers receiving the SMUD Business Electricity Reports may see a change in the energy efficiency recommendations in future reports due to Ecology Action updating your business profile. Updating your business profile helps SMUD provide more relevant information in future reports.

Payee (If Customer, Insert Payee name)

Payee Federal Tax ID

Payee Address

City, State Zip Code



Customer Cost, after rebates, to execute all work orders presented in this proposal: \$74778.31

I have read and understood the Terms and Conditions. I certify that the information I have provided is true and correct.

IN WITNESS WHEREOF, the parties hereto have caused this Agreement to be executed by their duly authorized representatives as of the date set forth below

Customer: La Sierra (Carmichael Parks & Rec)
Customer Representative: Tarry Smith
5325 Engle Road
Citrus Heights, California 95608
(916) 343-9251
Email: tsmith@carmichaelpark.com

Sacramento Municipal Utility District Complete Energy Solutions
Program Representative: Toni Renee Vierra
Ecology Action
2230 Longport Court, Suite 130
Elk Grove, California 95060
Mobile: (707) 373-0815
Email: trvierra@ecoact.org

Customer Representative's Title

Program Representative's Printed Name

Customer Representative's Printed Name

Program Representative's Signature

Customer Representative's Signature

Date

Date

La Sierra Community Center
5325 Engle Road
Citrus Heights, California
95608

Appendix A: Recommendations and Savings Checklist

Solution Key
AHO: Annual Avg. Hours of Operation
kWh: Annual kiloWatt Hours
kW: kiloWatt Load
Watts: Watts as published by the manufacturer

Area: (1) Building #1 - Suite #100 - Front Office

7	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.42	3120.0	1310.40	7	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.25	3120.0	786.24	\$229.59	\$83.08
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$28.11
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$440.70	\$111.19

Area: (2) Building #1 - Suite #100 - Rec Office

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$98.41	\$35.61
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$309.52	\$35.61

Area: (3) Building #1 - John Smith Hall - Kitchen - Main Area

32	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.92	3120.0	5990.40	32	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	1.15	3120.0	3594.24	\$1,079.85	\$395.48
1	Exit 15A w/Emergency Light	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.00	8760.0	35.04	\$129.60	\$23.94
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$111.03	\$128.48
						1	Control Occupancy Ceiling Dual Technology					\$206.70	\$0.00
												\$1,527.18	\$547.90

Area: (4) Building #1 - John Smith Hall - Kitchen - Over Stoves

2	INC 60A	60.0	0.12	4368.0	524.16	2	LED Screw-in A19 10w 3000K TCP	10.0	0.02	4368.0	87.36	\$33.12	\$53.66
												\$33.12	\$53.66

Area: (5) Building #1 - John Smith Hall - Kitchen - Storage Room #1 - R/Side

2	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.24	3120.0	736.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$72.59	\$70.19
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$112.34	\$0.00
												\$300.51	\$78.22

Area: (7) Building #1 - John Smith Hall - Kitchen - Storage Room #2 - R/Side

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.12	\$11.51
												\$34.12	\$11.51

Area: (8) Building #1 - John Smith Hall - Kitchen - Janitorial/Mop Room

3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$104.58	\$34.54
						1	Control Occupancy Wall Box					\$118.50	\$0.00
												\$223.08	\$34.54

Area: (9) Building #1 - John Smith Hall - Kitchen - Locker Room

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$64.19	\$19.31
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$174.28	\$19.31

Area: (10) Building #1 - John Smith Hall - Kitchen - Locker Room - Restroom

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
												\$32.10	\$11.51

Area: (11) Building #1 - John Smith Hall - "West Conf" Office

8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$262.40	\$94.95
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$32.12
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$573.97	\$127.07

Area: (12) Building #1 - John Smith Hall - Kitchen - Chair Storage

3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$98.41	\$34.54
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$208.50	\$34.54

Area: (13) Building #1 - John Smith Hall - Kitchen - Cart Storage

3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$98.41	\$34.54
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$208.50	\$34.54
Area: (14) Building #1 - John Smith Hall - Main Hall													
60	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	7.08	3120.0	22089.60	60	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	2.16	3120.0	6739.20	\$2,229.21	\$2,097.83
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$119.09	\$240.90
						1	Control Occupancy Ceiling Dual Technology					\$211.53	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$115.84	\$0.00
												\$2,675.67	\$2,338.73
Area: (15) Building #1 - Hall Between John Smith Hall and Chautauqua Playhouse													
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$262.40	\$92.10
6	INC 65R	65.0	0.39	3120.0	1216.80	6	LED Screw-in PAR38 17w 3000K 40deg TCP	17.0	0.10	3120.0	318.24	\$234.43	\$122.07
3	Exit 15A w/Emergency Light	30.0	0.09	8760.0	788.40	3	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	105.12	\$388.84	\$77.54
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$989.60	\$291.71
Area: (16) Building #1 - Hall Between John Smith Hall and Chautauqua - Restroom - M													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$343.67	\$11.51
Area: (17) Building #1 - Hall Between John Smith Hall and Chautauqua - Restroom - W													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$343.67	\$11.51
Area: (18) Building #1 - Hall Between John Smith Hall and Chautauqua - Janitor's Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$142.19	\$11.51
Area: (19) Building #1 - Chautauqua Playhouse - Small Prop Room													
12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	1456.0	1048.32	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	1456.0	628.99	\$418.35	\$77.01
						1	Control Occupancy Wall Box					\$118.50	\$0.00
												\$536.85	\$77.01
Area: (20) Building #1 - Chautauqua Playhouse - Costume Room #1													
2	T12 4' 40S 1L	48.0	0.10	1459.92	140.15	2	LED T8 4' 15w (18w DLC) 1L 5000K TCP	18.0	0.04	1459.92	52.56	\$115.14	\$14.84
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$225.23	\$14.84
Area: (21) Building #1 - Chautauqua Playhouse - Costume Room #2													
1	T12 4' 40S 1L	48.0	0.05	1456.0	69.89	1	LED T8 4' 15w (18w DLC) 1L 5000K TCP	18.0	0.02	1456.0	26.21	\$57.57	\$7.41
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$167.66	\$7.41
Area: (22) Building #1 - Chautauqua Playhouse - Costume Room #3													
2	INC 60A	60.0	0.12	3120.0	374.40	2	LED Screw-in A19 10w 3000K TCP	10.0	0.02	3120.0	62.40	\$33.12	\$41.63
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$143.21	\$41.63
Area: (23) Building #1 - Chautauqua Playhouse - Costume Room #4 (Flowers)													
2	INC 60A	60.0	0.12	3120.0	374.40	2	LED Screw-in A19 10w 3000K TCP	10.0	0.02	3120.0	62.40	\$33.12	\$41.63
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$143.21	\$41.63
Area: (24) Building #1 - Chautauqua Playhouse - Large Prop Room													
16	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	1.49	1459.92	2172.36	16	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.58	1459.92	840.91	\$592.63	\$226.24
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$121.54	\$37.56
						1	Control Occupancy Ceiling Dual Technology					\$213.00	\$0.00
												\$927.17	\$263.80
Area: (25) Building #1 - Chautauqua Playhouse - Hall													
4	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.37	1456.0	541.63	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	1456.0	209.66	\$134.06	\$56.46

2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$51.69
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$9.37
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$670.58	\$143.37
Area: (26) Building #1 - Chautauqua Playhouse - Office Supply Room													
2	INC 60A	60.0	0.12	3120.0	374.40	2	LED Screw-in A19 10w 3000K TCP	10.0	0.02	3120.0	62.40	\$33.12	\$41.63
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$143.21	\$41.63
Area: (27) Building #1 - Chautauqua Playhouse - Box Office													
2	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.24	1456.0	343.62	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	1456.0	104.83	\$68.46	\$39.44
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$178.55	\$39.44
Area: (28) Building #1 - Chautauqua Playhouse - Box Office - Interior Office													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	1456.0	174.72	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	1456.0	104.83	\$64.19	\$13.17
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$174.28	\$13.17
Area: (29) Building #1 - Chautauqua Playhouse - Office R/side of Supply Room													
2	INC 60A	60.0	0.12	3120.0	374.40	2	LED Screw-in A19 10w 3000K TCP	10.0	0.02	3120.0	62.40	\$33.12	\$40.57
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$143.21	\$40.57
Area: (30) Building #1 - Chautauqua Playhouse - Theater													
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	1456.0	698.88	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	1456.0	419.33	\$278.90	\$57.31
5	INC 65R	65.0	0.32	3120.0	1014.00	5	LED Screw-in PAR38 17w 3000K 40deg TCP	17.0	0.08	3120.0	265.20	\$200.23	\$92.01
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$48.30
												\$738.37	\$197.62
Area: (31) Building #1 - Chautauqua Playhouse - Theater - Workshop													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	1456.0	349.44	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	1456.0	209.66	\$128.38	\$23.20
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$9.37
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$439.95	\$32.57
Area: (32) Building #170 - Restroom - Uni													
1	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.09	3120.0	290.16	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$33.53	\$24.93
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$4.02
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$345.10	\$28.95
Area: (33) Building #170 - Lobby													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3128.4	375.41	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$2.80	\$20.43
1	Exit 15A w/Emergency Light	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.00	8760.0	35.04	\$129.60	\$24.79
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.05
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$343.51	\$53.27
Area: (34) Building #170 - Playroom NXT Lobby													
3	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.35	3120.0	1104.48	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$102.71	\$98.80
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$12.05
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$313.82	\$110.85
Area: (35) Building #170 - Restroom - M													
2	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.24	3128.4	738.30	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$68.46	\$70.34
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.05
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$380.03	\$78.39
Area: (36) Building #170 - Hall with Solar Tubes													

3	Exit 15A w/Emergency Light	30.0	0.09	8760.0	788.40	3	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	105.12	\$388.84	\$77.54
												\$388.84	\$77.54
Area: (37) Building #170 - Storage (Off Hall - No Door)													
1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$20.82
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.29	\$20.82
Area: (38) Building #170 - Classroom NXT Storage w/o doors													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3128.4	1126.22	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3128.4	675.73	\$8.60	\$68.68
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$320.17	\$68.68
Area: (39) Building #170 - Classroom NXT Storage w/o doors - Foyer Area													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3128.4	187.70	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3128.4	112.62	\$1.40	\$11.54
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$111.49	\$11.54
Area: (40) Building #170 - Ms. Diane's Office													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$2.88	\$23.74
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$213.99	\$31.77
Area: (41) Building #170 - Ms. Treka & Ms. Fe's Office													
12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	3120.0	2246.40	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	3120.0	1347.84	\$17.18	\$142.42
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$48.18
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$228.29	\$190.60
Area: (42) Building #170 - Restroom - W													
2	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.24	3120.0	736.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$68.46	\$70.19
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$380.03	\$78.22
Area: (43) Building #170 - Large Classroom (with sink)													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$25.78	\$205.59
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$72.27
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$350.79	\$277.86
Area: (44) Sierra Room #1 - Main Area													
24	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	2.23	3120.0	6963.84	24	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.86	3120.0	2695.68	\$804.38	\$584.64
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$49.57
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$96.36
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$1,375.19	\$730.57
Area: (45) Sierra Room #1 - Storage													
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$4.30	\$34.54
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$4.30	\$34.54
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$12.05
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$12.05
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$449.19	\$93.18
Area: (46) Sierra Room #1 - "Scary Room"													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3128.4	1126.22	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3128.4	675.73	\$8.60	\$68.68
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$24.14
												\$124.18	\$92.82
Area: (47) Sierra Room #2 - Main Area													



24	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	2.23	3120.0	6963.84	24	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.86	3120.0	2695.68	\$804.38	\$598.32
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$51.69
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$96.36
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$1,375.19	\$746.37
Area: (48) Sierra Room #2 - Storage													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3128.4	375.41	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$2.88	\$23.08
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$8.05
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$327.89	\$31.13
Area: (49) Building #165 - Media Room													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$5.73	\$47.47
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$16.06
												\$112.91	\$63.53
Area: (50) Building #165 - Restroom - W													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$2.88	\$23.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
												\$110.06	\$31.06
Area: (51) Building #165 - Restroom - M													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$2.88	\$23.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$314.45	\$31.06
Area: (52) Building #165 - Janitor's Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$1.40	\$11.51
3	Exit 15A w/Emergency Light	30.0	0.09	8760.0	788.40	3	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	105.12	\$388.84	\$77.54
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$500.33	\$89.05
Area: (53) Building #165 - Staff Lounge													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$23.03
Area: (54) Building #165 - Staff Lounge - Restroom													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
												\$32.10	\$11.51
Area: (55) Building #165 - Kitchen													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$24.72
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$32.75
Area: (56) Building #165 - Office													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.74
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$31.77
Area: (57) Building #165 - Storage Room													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$31.06
Area: (58) Building #165 - Entry Foyer													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
												\$65.61	\$23.03

Area: (59) Building #165 - Main Room

24	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.44	3120.0	4492.80	24	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.86	3120.0	2695.68	\$836.70	\$309.52
3	Exit 15A w/Emergency Light	30.0	0.09	8760.0	788.40	3	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	105.12	\$388.84	\$71.82
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$96.36
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$1,550.55	\$477.70

Area: (60) Johnson Gym - Main Area

8	INC 300A	300.0	2.40	3120.0	7488.00	8	Fixtures Removed (Other)	0.0	0.00	3120.0	0.00	\$291.08	\$920.08
16	T8-4'-32w-1st Gen-6lamp-EI-RS-NLO	182.0	2.91	3120.0	9085.44	16	LED Retrofit Strips 4ft 2pc 72w 5000K 10800L Linmore	76.0	1.22	3120.0	3793.92	\$3,256.89	\$675.88
4	Exit 15A w/Emergency Light	30.0	0.12	8760.0	1051.20	4	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.02	8760.0	140.16	\$518.45	\$96.60
												\$4,066.42	\$1,692.56

Area: (61) Johnson Gym - Scorekeeper's Area

3	INC 100A	100.0	0.30	4368.0	1310.40	3	LED Screw-in A19 18w 3000K TCP	18.0	0.05	4368.0	235.87	\$99.01	\$132.00
												\$99.01	\$132.00

Area: (62) Johnson Gym - Old Telephone Closet

1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$20.82
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.29	\$20.82

Area: (63) Johnson Gym - Panel Room

1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$18.79
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.29	\$18.79

Area: (64) Johnson Gym - Entry Foyer

8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$290.58	\$92.10
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$51.69
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$121.54	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$213.00	\$0.00
												\$884.36	\$143.79

Area: (65) Johnson Gym - Restroom - W

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	4368.0	262.08	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$32.10	\$15.33
												\$32.10	\$15.33

Area: (66) Johnson Gym - Snack Bar - Main Area

4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$49.44
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$342.32	\$49.44

Area: (67) Johnson Gym - Snack Bar - R/Room

1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$19.92
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.29	\$19.92

Area: (68) Johnson Gym - Snack Bar - L/Room

1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$19.92
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.29	\$19.92

Area: (69) Johnson Gym - Restroom - M

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	4368.0	262.08	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$32.10	\$15.33
												\$32.10	\$15.33

Area: (70) Johnson Gym - Equipment Rrom

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	4368.0	524.16	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	4368.0	314.50	\$65.61	\$30.67
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$30.67

Area: (71) West Room - Between Johnson & Villareal Gyms

12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	3120.0	2246.40	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	3120.0	1347.84	\$435.86	\$137.06
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$121.54	\$48.18
						1	Control Occupancy Ceiling Dual Technology					\$213.00	\$0.00

											\$770.40	\$185.24	
Area: (72) Villareal Gym - Main Area													
16	T8-4'-32w-1st Gen-6lamp-EI-RS-NLO	182.0	2.91	3120.0	9085.44	16	LED Retrofit Strips 4ft 2pc 72w 5000K 10800L Linmore	76.0	1.22	3120.0	3793.92	\$3,256.89	\$675.88
4	Exit 15A w/Emergency Light	30.0	0.12	8760.0	1051.20	4	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.02	8760.0	140.16	\$518.45	\$96.60
											\$3,775.34	\$772.48	
Area: (73) Villareal Gym - Restroom - M													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$69.71	\$23.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$8.03
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
											\$394.72	\$31.06	
Area: (74) Villareal Gym - Janitor's Room													
1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.20	\$20.82
						1	Control Occupancy Wall Box					\$110.09	\$0.00
											\$126.29	\$20.82	
Area: (75) Villareal Gym - Restroom - W													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$69.71	\$23.03
2	T12 4' 40S 1L	48.0	0.10	3120.0	299.52	2	LED T8 4' 15w (18w DLC) 1L 5000K TCP	18.0	0.04	3120.0	112.32	\$117.68	\$26.15
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
											\$396.82	\$49.18	
Area: (76) Villareal Gym - Equipment Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	4368.0	262.08	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$32.10	\$15.33
						1	Control Occupancy Wall Box					\$110.09	\$0.00
											\$142.19	\$15.33	
Area: (77) Building #200 - Elizabeth's Office													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$47.47
						1	Control Occupancy Wall Box					\$110.09	\$0.00
											\$241.30	\$47.47	
Area: (79) Building #200 - Vice Principal's Office													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$139.45	\$47.47
						1	Control Occupancy Wall Box					\$118.50	\$0.00
											\$257.95	\$47.47	
Area: (80) Building #200 - Copy Room													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$69.08
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$24.09
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
											\$407.93	\$93.17	
Area: (81) Building #200 - Copy Room - Safe Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$65.61	\$23.03
						1	Control Occupancy Wall Box					\$110.09	\$0.00
											\$175.70	\$23.03	
Area: (82) Building #200 - New Principal's Office													
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$278.90	\$94.95
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$32.12
						1	Control, Wireless, Lutron Corner Mount Sensor					\$112.34	\$0.00
											\$506.82	\$127.07	
Area: (83) Building #200 - Angela's Office													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$47.47
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
											\$342.32	\$47.47	
Area: (84) Building #200 - Office NXT Angela's Office													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1	Control Occupancy Wall Box					\$110.09	\$0.00
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$4.02
											\$249.37	\$15.89	
Area: (85) Building #200 - Office NXT Angela's Office - Interior Office													

4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$47.47
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$345.23	\$47.47
Area: (86) Building #200 - Breakroom													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$74.15
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$508.39	\$74.15
Area: (87) Building #200 - Pacific Room - Main Area													
17	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.02	3120.0	3182.40	17	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.61	3120.0	1909.44	\$592.67	\$194.17
56	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	3.36	3120.0	10483.20	56	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	2.02	3120.0	6289.92	\$2,000.40	\$639.61
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$119.09	\$224.84
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$68.26
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$3,037.17	\$1,126.88
Area: (88) Building #200 - Pacific Room - Storage													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$46.05
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$16.06
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$342.32	\$62.11
Area: (89) Building #200 - Autism Office													
13	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.78	3120.0	2433.60	13	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.47	3120.0	1460.16	\$426.40	\$148.48
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$52.20
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$737.97	\$200.68
Area: (90) Building #200 - Room R/Autism Office													
9	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.54	3120.0	1684.80	9	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.32	3120.0	1010.88	\$295.20	\$102.79
1	INC 60A	60.0	0.06	4368.0	262.08	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	4368.0	43.68	\$16.57	\$26.60
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$421.86	\$129.39
Area: (91) Building #200 - Restroom NXT Autism Office													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						2	Control Occupancy Wall Box					\$220.17	\$0.00
												\$285.78	\$23.03
Area: (92) Building #200 - Blue Whale Room													
13	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.78	3120.0	2433.60	13	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.47	3120.0	1460.16	\$426.40	\$148.48
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$52.20
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$737.97	\$200.68
Area: (94) Building #200 - Lounge - Main Area													
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$98.41	\$34.54
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$12.05
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$309.52	\$46.59
Area: (97) Building #200 - Chris Blunt's Office													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$47.47
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$241.30	\$47.47
Area: (99) Building #200 - Room 250 - Restroom - M													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$4.02
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$343.67	\$15.53

Area: (100) Building #200 - Room 250 - Foyer - Men's Restroom Side

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$142.19	\$11.51

Area: (101) Building #200 - Room 250 - Main Area

9	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.54	3120.0	1684.80	9	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.32	3120.0	1010.88	\$295.20	\$102.79
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$36.14
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$606.77	\$138.93

Area: (102) Building #200 - Room 250 - Restroom - W

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$4.02
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$343.67	\$15.53

Area: (103) Building #200 - Room 250 - Foyer - Womens' RR Side

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$4.02
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$243.21	\$15.53

Area: (104) Building #200 - Room 255 - Main Area

13	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.78	3120.0	2433.60	13	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.47	3120.0	1460.16	\$426.40	\$148.48
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$52.20
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$737.97	\$200.68

Area: (105) Building #200 - Room 255 - Breakroom

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$142.19	\$11.51

Area: (106) Building #200 - Room 260

18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$590.41	\$205.59
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$72.27
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$901.98	\$277.86

Area: (107) Building #200 - Room 265

6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$68.53
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$24.09
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$508.39	\$92.62

Area: (108) Building #200 - Room 270

10	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.60	3120.0	1872.00	10	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.36	3120.0	1123.20	\$328.00	\$114.22
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$40.15
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$639.57	\$154.37

Area: (109) Building #300 - Rooms 300/305/310/315/320/325

36	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	2.16	3128.4	6757.34	36	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	1.30	3128.4	4054.41	\$1,742.46	\$412.09
						6	Control, Wireless, Lutron Wall-Box Switch (5A)					\$666.18	\$144.84
						6	Control Occupancy Ceiling Dual Technology					\$1,240.20	\$0.00
												\$3,648.84	\$556.93

Area: (110) Building #300 - Restroom - M

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	4368.0	524.16	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	4368.0	314.50	\$65.61	\$30.67
												\$65.61	\$30.67

Area: (112) Building #300 - Restroom - W

3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$148.56	\$34.54
												\$148.56	\$34.54

Area: (113) Building #300 - Rooms 330/335/340/345/350

30	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.80	3120.0	5616.00	30	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	1.08	3120.0	3369.60	\$1,485.57	\$342.65
						5	Control, Wireless, Lutron Wall-Box Switch (5A)					\$577.92	\$120.45
						5	Control Occupancy Ceiling Dual Technology					\$1,047.16	\$0.00
												\$3,110.65	\$463.10

Area: (114) Building #400 - Rooms 400/405/410/415/420/425

36	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	2.16	3120.0	6739.20	36	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	1.30	3120.0	4043.52	\$1,214.83	\$411.18
						6	Control, Wireless, Lutron Wall-Box Switch (5A)					\$666.18	\$144.54
						6	Control Occupancy Ceiling Dual Technology					\$1,240.20	\$0.00
												\$3,121.21	\$555.72

Area: (115) Building #400 - Rooms 430/435/440

27	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.62	3120.0	5054.40	27	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.97	3120.0	3032.64	\$941.28	\$308.38
						3	Control, Wireless, Lutron Wall-Box Switch (5A)					\$346.75	\$108.41
						3	Control Occupancy Ceiling Dual Technology					\$628.30	\$0.00
												\$1,916.33	\$416.79

Area: (116) Building #400 - Rooms 445/450

12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	3120.0	2246.40	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	3120.0	1347.84	\$418.35	\$137.06
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$48.18
						2	Control Occupancy Ceiling Dual Technology					\$418.86	\$0.00
												\$1,068.38	\$185.24

Area: (117) Building #500 - Restroom - W

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	4368.0	524.16	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	4368.0	314.50	\$65.61	\$30.67
												\$65.61	\$30.67

Area: (118) Building #500 - Janitor's Room

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.12	\$11.51
						1	Control Occupancy Wall Box					\$118.50	\$0.00
												\$152.62	\$11.51

Area: (119) Building #500 - Restroom - M

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$99.03	\$23.03
												\$99.03	\$23.03

Area: (120) Building #500 - Room 520

6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$209.16	\$68.53
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$24.09
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$534.17	\$92.62

Area: (121) Building #500 - Rooms 525/530

18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$627.51	\$205.59
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$0.00
						2	Control Occupancy Ceiling Dual Technology					\$418.86	\$0.00
												\$1,277.54	\$205.59

Area: (122) Building #500 - Rooms 525/530 - Storage in between rooms

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.12	\$11.51
						1	Control Occupancy Wall Box					\$118.50	\$0.00
												\$152.62	\$11.51

Area: (123) Building #500 - Room 535

9	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.54	3120.0	1684.80	9	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.32	3120.0	1010.88	\$313.77	\$102.79
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$36.14
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$638.78	\$138.93

Area: (124) Building #500 - Room 535 - Storage Area

4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$139.45	\$46.05
						1	Control Occupancy Wall Box					\$118.50	\$0.00
												\$257.95	\$46.05

Area: (125) Building #500 - Room 500

6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$209.16	\$68.53
---	--------------------------------------	------	------	--------	---------	---	---	------	------	--------	--------	----------	---------

						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$115.58	\$24.09
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$534.17	\$92.62
Area: (126) Building #500 - Rooms 505/510/515													
27	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.62	3120.0	5054.40	27	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.97	3120.0	3032.64	\$941.28	\$308.38
						3	Control, Wireless, Lutron Wall-Box Switch (5A)					\$346.75	\$108.41
						3	Control Occupancy Ceiling Dual Technology					\$628.30	\$0.00
												\$1,916.33	\$416.79
Area: (127) Building #500 - Room 510/515 - Closet													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
2	INC 100A	100.0	0.20	3120.0	624.00	2	LED Screw-in A19 18w 3000K TCP	18.0	0.04	3120.0	112.32	\$63.26	\$68.43
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$205.45	\$79.94
Area: (129) Building #600 - Rooms 600/605/610													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$627.51	\$205.59
						3	Control, Wireless, Lutron Wall-Box Switch (5A)					\$346.75	\$72.27
						3	Control Occupancy Ceiling Dual Technology					\$628.30	\$0.00
												\$1,602.56	\$277.86
Area: (130) Building #600 - Rooms 615/620													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$627.51	\$205.59
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$72.27
						2	Control Occupancy Ceiling Dual Technology					\$418.86	\$0.00
												\$1,277.54	\$277.86
Area: (131) Building #600 - Room 620 - Storage													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$23.03
Area: (132) Building #600 - Room 615 - Kitchette													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$24.72
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$24.72
Area: (133) Building #600 - Rooms 625/630/635													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$627.51	\$205.59
						3	Control, Wireless, Lutron Wall-Box Switch (5A)					\$346.75	\$72.27
						3	Control Occupancy Ceiling Dual Technology					\$628.30	\$0.00
												\$1,602.56	\$277.86
Area: (134) Building #600 - Rooms 640/645													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$627.51	\$205.59
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$72.27
						2	Control Occupancy Ceiling Dual Technology					\$418.86	\$0.00
												\$1,277.54	\$277.86
Area: (135) Building #600 - Room 640 - Storage													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$23.03
Area: (136) Building #600 - Room 645 - Storage													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$23.03
Area: (138) Building #700 - Gibbon's Annex - Supply Room "Material Resources"													
12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	3120.0	2246.40	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	3120.0	1347.84	\$569.48	\$138.15
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$48.18
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$780.59	\$186.33
Area: (139) Building #700 - Gibbon's Annex - Foyer - L/Restroom Area													

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$46.44	\$11.51
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$156.53	\$11.51
Area: (140) Building #700 - Gibbon's Annex - Equipment Room off Foyer													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$46.44	\$9.65
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$156.53	\$9.65
Area: (141) Building #700 - Gibbon's Annex - Conference Room #1													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$94.92	\$22.84
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$322.95	\$30.87
Area: (142) Building #700 - Gibbon's Annex - Conference Room #1 - ADJ Hallway													
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$142.38	\$34.54
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$353.49	\$34.54
Area: (143) Building #700 - Gibbon's Annex - Sink Room NXT Conference Room #1													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$94.92	\$23.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$8.03
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$306.03	\$31.06
Area: (144) Building #700 - Gibbon's Annex - Main Hallway													
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$148.56	\$34.54
3	T12 U-Lamp 2L	72.0	0.22	3120.0	673.92	3	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.07	3120.0	205.92	\$336.04	\$64.20
1	Exit 15A w/Emergency Light	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.00	8760.0	35.04	\$129.60	\$25.85
2	Exit 15A	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w Red (SMUD)	4.0	0.01	8760.0	70.08	\$132.36	\$51.69
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$12.05
						1	Control, Wireless, Lutron Hallway Sensor					\$112.34	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$112.34	\$0.00
												\$1,306.34	\$188.33
Area: (145) Building #700 - Gibbon's Annex - "CMP"													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	4368.0	262.08	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$32.10	\$15.33
												\$32.10	\$15.33
Area: (146) Building #700 - Gibbon's Annex - Large Meeting Room													
19	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.14	3120.0	3556.80	19	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.68	3120.0	2134.08	\$940.87	\$217.01
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$49.57
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$24.79
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$231.17	\$76.29
						1	Control Occupancy Ceiling Dual Technology					\$209.43	\$0.00
												\$1,706.88	\$367.66
Area: (147) Building #700 - Gibbon's Annex - Electrical Room													
3	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.18	3120.0	561.60	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$148.56	\$28.96
						1	Control Occupancy Wall Box					\$118.50	\$0.00
						2	Control Occupancy Wall Box					\$236.98	\$0.00
												\$504.04	\$28.96
Area: (148) Building #700 - Gibbon's Annex - Chair Room													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	4368.0	524.16	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	4368.0	314.50	\$65.61	\$30.67
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$30.67
Area: (149) Building #700 - Gibbon's Annex - Kitchen													
2	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.24	3128.4	738.30	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$68.46	\$69.00

1	Exit 15A w/Emergency Light	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.00	8760.0	35.04	\$129.60	\$23.94
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$409.17	\$92.94
Area: (150) Building #700 - Gibbon's Annex - Restroom Foyer													
1	Exit 15A w/Emergency Light	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.00	8760.0	35.04	\$129.60	\$25.85
												\$129.60	\$25.85
Area: (151) Building #700 - Gibbon's Annex - East Wing - Restroom - Uni (in Hallway)													
1	INC 60A	60.0	0.06	3120.0	187.20	1	LED Screw-in A19 10w 3000K TCP	10.0	0.01	3120.0	31.20	\$16.57	\$20.82
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$126.66	\$20.82
Area: (152) Building #700 - Gibbon's Annex - East Wing - Admin Breakroom													
1	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.12	3120.0	368.16	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.23	\$35.09
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$277.44	\$46.60
Area: (153) Building #700 - Gibbon's Annex - East Wing - Server Room													
1	T12 4' 40S 1L	48.0	0.05	3120.0	149.76	1	LED T8 4' 15w (18w DLC) 1L 5000K TCP	18.0	0.02	3120.0	56.16	\$57.57	\$13.07
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$167.66	\$13.07
Area: (155) Building #700 - Gibbon's Annex - East Wing - Large Office (Breakroom side)													
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$262.40	\$94.95
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$24.79
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	4368.0	2096.64	8	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	4368.0	1257.98	\$262.40	\$126.66
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Wall Box					\$110.09	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$1,119.81	\$246.40
Area: (156) Building #700 - Gibbon's Annex - East Wing - File Box Room (NXT to Large Office)													
2	T12 U-Lamp 2L	72.0	0.14	3120.0	449.28	2	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.04	3120.0	137.28	\$224.04	\$42.80
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$334.13	\$42.80
Area: (157) Building #700 - Gibbon's Annex - East Wing - Murray Office													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$47.47
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$235.14	\$47.47
Area: (158) Building #700 - Gibbon's Annex - East Wing - Conference Room NXT Murray Office													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$69.08
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$508.39	\$69.08
Area: (159) Building #700 - Gibbon's Annex - East Wing - Nicky's Office													
1	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.12	3120.0	368.16	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.23	\$31.22
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$144.32	\$31.22
Area: (160) Building #700 - Gibbon's Annex - East Wing - Nicky's Office - Conference Room													
1	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.12	3120.0	368.16	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.23	\$35.09
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$144.32	\$35.09
Area: (161) Building #700 - Gibbon's Annex - East Wing - Hall NXT Nicky's Office													
3	T12 U-Lamp 2L	72.0	0.22	3120.0	673.92	3	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.07	3120.0	205.92	\$336.04	\$64.20
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00

						1 Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
											\$547.15	\$64.20
Area: (162) Building #700 - Gibbon's Annex - East Wing - McGreal Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box					\$110.09	\$0.00
						1 Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
											\$246.12	\$11.87
Area: (163) Building #700 - Gibbon's Annex - East Wing - Coates Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box					\$110.09	\$0.00
						1 Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
											\$246.12	\$11.87
Area: (164) Building #700 - Gibbon's Annex - East Wing - Julie's Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box					\$110.09	\$0.00
						1 Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
											\$246.12	\$11.87
Area: (165) Building #700 - Gibbon's Annex - East Wing - Foyer NXT Julie's Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
2	Exit 15A	30.0	0.06	8760.0	525.60	2 LED Exit Fixture 4w Red (SMUD)	4.0	0.01	8760.0	70.08	\$132.36	\$51.69
						1 Control Occupancy Wall Box					\$110.09	\$0.00
											\$274.55	\$63.20
Area: (166) Building #700 - Gibbon's Annex - East Wing - Brown's Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
											\$152.95	\$11.87
Area: (167) Building #700 - Gibbon's Annex - East Wing - Hartley's Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
											\$152.95	\$11.87
Area: (168) Building #700 - Gibbon's Annex - East Wing - Corrigan Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
											\$152.95	\$11.87
Area: (169) Building #700 - Gibbon's Annex - East Wing - Shelley Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
											\$152.95	\$11.87
Area: (170) Building #700 - Gibbon's Annex - East Wing - Percoski Office												
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.87
						1 Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
											\$152.95	\$11.87
Area: (171) Building #700 - Gibbon's Annex - East Wing - Board Room NXT Percoski's Office												
8	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.48	3120.0	1497.60	8 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.29	3120.0	898.56	\$262.40	\$92.10
1	Exit 15A	30.0	0.03	8760.0	262.80	1 LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1 Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1 Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
											\$640.14	\$117.95
Area: (172) Building #700 - Gibbon's Annex - East Wing - Hall ADJ Klagenberg												
5	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.30	3120.0	936.00	5 LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.18	3120.0	561.60	\$164.01	\$57.56
1	Exit 15A	30.0	0.03	8760.0	262.80	1 LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1 Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1 Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
											\$441.29	\$83.41
Area: (173) Building #700 - Gibbon's Annex - East Wing - Interior Cubicle Area												

12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	4368.0	3144.96	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	4368.0	1886.98	\$393.61	\$189.99
												\$393.61	\$189.99
Area: (174) Building #700 - Gibbon's Annex - East Wing - Hall ACF McGreal Office													
2	T12 U-Lamp 2L	72.0	0.14	3120.0	449.28	2	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.04	3120.0	137.28	\$224.04	\$42.80
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$435.15	\$42.80
Area: (175) Building #700 - Gibbon's Annex - East Wing - Hall ADJ Brown Office													
4	T12 U-Lamp 2L	72.0	0.29	3120.0	898.56	4	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.09	3120.0	274.56	\$448.06	\$85.61
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$659.17	\$85.61
Area: (176) Building #700 - Gibbon's Annex - East Wing - Hall ADJ Board Room													
2	T12 U-Lamp 2L	72.0	0.14	3120.0	449.28	2	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.04	3120.0	137.28	\$224.04	\$42.80
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$435.15	\$42.80
Area: (177) Building #700 - Gibbon's Annex - East Wing - Shelley Office (Exterior Access)													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	4368.0	262.08	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$32.10	\$15.83
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$152.95	\$15.83
Area: (178) Building #800 - Panel Room #1 NXT Room 835													
1	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.12	4368.0	515.42	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	4368.0	157.25	\$34.23	\$41.03
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$345.80	\$41.03
Area: (179) Building #800 - Panel Room #2 NXT Room 835 (smaller room)													
1	T8-4'-32w-1st Gen-4lamp-EI-RS-NLO	118.0	0.12	3120.0	368.16	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$34.23	\$31.22
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$345.80	\$31.22
Area: (180) Building #800 - Foyer ADJ Room 830													
3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$371.47	\$26.24
Area: (181) Building #800 - Foyer ADJ Room 830 - Restroom - M													
3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$405.76	\$0.39
Area: (182) Building #800 - Foyer ADJ Room 830 - Restroom - W													
3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$405.76	\$0.39
Area: (183) Building #800 - Room 835													
7	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.22	3120.0	698.88	7	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.25	3120.0	786.24	\$219.77	\$6.23
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$430.88	\$6.23
Area: (184) Building #800 - Room 835 - Room ADJ 835													

4	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.13	3120.0	399.36	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$125.58	\$3.56
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$336.69	\$3.56

Area: (185) Building #800 - Room 830 - Main Area

9	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.29	3120.0	898.56	9	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.32	3120.0	1010.88	\$282.56	\$8.02
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$594.13	\$8.02

Area: (186) Building #800 - Room 830 - Rear Room NXT Breakroom

4	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.13	3120.0	399.36	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$125.58	\$3.56
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$24.79
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$402.86	\$28.35

Area: (187) Building #800 - Room 830 - Breakroom

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	4368.0	524.16	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	4368.0	314.50	\$65.61	\$30.67
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$175.70	\$30.67

Area: (188) Building #800 - Room 830 - Storage Room

3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$204.28	\$0.39

Area: (189) Building #800 - Room 830 - Lobby

6	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.56	3120.0	1740.96	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$201.09	\$149.58
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$388.11	\$175.43

Area: (191) Building #800 - Room 825 - Sink Area

2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$1.78
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$183.64	\$1.78

Area: (192) Building #800 - Room 825 - Room #2

4	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.13	3120.0	399.36	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$125.58	\$3.56
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$246.43	\$3.56

Area: (193) Building #800 - Room 825 - Room #3

3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$2.67
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$215.04	\$2.67

Area: (194) Building #800 - Room 825 - Room #4

3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$2.67
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$215.04	\$2.67

Area: (195) Building #800 - Room 825 - Room #5

2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$1.78
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$183.64	\$1.78

Area: (196) Building #800 - Room 825 - Room #6

3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$2.67
						1	Control Occupancy Wall Box Dual Switch					\$120.85	\$0.00
												\$215.04	\$2.67

Area: (197) Building #800 - Room 825 - Lobby ADJ Room #9

2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$0.26
---	--------------------------------------	------	------	--------	--------	---	---	------	------	--------	--------	---------	--------

2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$0.26
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$399.61	\$26.37
Area: (198) Building #800 - Room 825 - Room #8													
1	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.03	3120.0	99.84	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$31.40	\$0.89
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$141.49	\$0.89
Area: (199) Building #800 - Room 825 - Room #9													
4	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.37	3120.0	1160.64	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$134.06	\$99.23
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$452.35	\$99.23
Area: (200) Building #800 - Room 825 - Hallway ADJ Rooms 1-6													
1	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.03	3120.0	99.84	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$31.40	\$0.13
1	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.03	3120.0	99.84	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$31.40	\$0.13
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$214.35	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$381.08	\$0.26
Area: (201) Building #800 - Room 825 - Lobby													
4	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.37	3120.0	1160.64	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$134.06	\$99.72
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$518.52	\$125.57
Area: (202) Building #800 - Rooms 815/820 - Lobby													
3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
3	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.10	3120.0	299.52	3	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.11	3120.0	336.96	\$94.19	\$0.39
2	Exit 15A	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w Red (SMUD)	4.0	0.01	8760.0	70.08	\$132.36	\$51.69
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$639.03	\$52.47
Area: (203) Building #800 - Room 820A													
2	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.19	3120.0	580.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$67.03	\$49.61
2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$1.78
2	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.06	3120.0	199.68	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$62.79	\$1.78
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Wall Box					\$110.09	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$513.81	\$53.17
Area: (204) Building #800 - Room 820 - Office #2													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	4368.0	1048.32	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	4368.0	628.99	\$131.21	\$63.33
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$241.30	\$63.33
Area: (205) Building #800 - Room 820 - Office #3													
2	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.19	3120.0	580.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$67.03	\$49.61
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$278.14	\$49.61

Area: (206) Building #800 - Room 820 - Office #4

2	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.19	3128.4	581.88	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$67.03	\$49.72
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$278.14	\$49.72

Area: (207) Building #800 - Room 820 - Office #5

2	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.19	3120.0	580.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$67.03	\$49.61
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$278.14	\$49.61

Area: (208) Building #800 - Room 820 - Office #6

1	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.03	3120.0	99.84	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$31.40	\$0.89
1	T8-4'-32w-1st Gen-1lamp-EI-RS-NLO	32.0	0.03	3120.0	99.84	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$31.40	\$0.89
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$172.89	\$1.78

Area: (209) Building #800 - Room 820 - Sink Room ADJ Office #6

2	T8-4'-32w-1st Gen-3lamp-EI-RS-NLO	93.0	0.19	3120.0	580.32	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$67.03	\$49.86
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$278.14	\$49.86

Area: (210) Building #800 - Room 820 - Hallway

1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3120.0	187.20	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3120.0	112.32	\$32.10	\$11.51
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$214.35	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$350.38	\$11.51

Area: (211) Building #800 - Room 815 - Rear Room w/Sink

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.74
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$23.74

Area: (212) Building #800 - Room 815 - Office #1

6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$71.21
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$24.79
												\$262.99	\$96.00

Area: (213) Building #800 - Room 815 - Office #2

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3128.4	375.41	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3128.4	225.24	\$65.61	\$23.79
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$23.79

Area: (214) Building #800 - Room 815 - Office #3

2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.74
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control, Wireless, Lutron Corner Mount Sensor					\$103.93	\$0.00
												\$276.72	\$23.74

Area: (215) Building #800 - Main Hallway

12	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.72	3128.4	2252.45	12	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.43	3128.4	1351.47	\$393.61	\$138.46
2	Exit 15A w/Emergency Light	30.0	0.06	8760.0	525.60	2	LED Exit Fixture 4w w/Emergency Light Red (SMUD)	4.0	0.01	8760.0	70.08	\$259.24	\$51.69
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
						2	Control, Wireless, Lutron Wall-Box Switch (5A)					\$214.35	\$0.00
						1	Control, Wireless, Lutron Hallway Sensor					\$103.93	\$0.00
												\$1,037.30	\$216.00

Area: (216) Building #800 - Room 810 - Cypress Room

24	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.44	3120.0	4492.80	24	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.86	3120.0	2695.68	\$787.21	\$274.12
3	Exit 15A	30.0	0.09	8760.0	788.40	3	LED Exit Fixture 4w Red (SMUD)	4.0	0.01	8760.0	105.12	\$198.52	\$74.36
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
												\$1,092.91	\$348.48
Area: (217) Building #800 - Room 810 - Kitchen													
5	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.30	3120.0	936.00	5	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.18	3120.0	561.60	\$164.01	\$61.79
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$368.40	\$61.79
Area: (218) Building #800 - Room 810 - Foyer NXT Kitchen													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.03
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$25.85
												\$131.78	\$48.88
Area: (219) Building #800 - "TR Services" - Main Area													
10	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.60	3120.0	1872.00	10	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.36	3120.0	1123.20	\$328.00	\$118.69
1	Exit 15A	30.0	0.03	8760.0	262.80	1	LED Exit Fixture 4w Red (SMUD)	4.0	0.00	8760.0	35.04	\$66.17	\$24.79
												\$394.17	\$143.48
Area: (220) Building #800 - "TR Services" - Stock Room													
2	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.12	3120.0	374.40	2	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.07	3120.0	224.64	\$65.61	\$23.74
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
												\$172.79	\$23.74
Area: (221) Building #800 - Restroom - W													
5	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.30	3120.0	936.00	5	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.18	3120.0	561.60	\$164.01	\$57.56
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
												\$271.19	\$57.56
Area: (222) Building #800 - Janitor's Room													
1	T12 2' 20w 2L	56.0	0.06	3120.0	174.72	1	LED T8 2' 8w (11w DLC) 2L 5000K Green Creative	22.0	0.02	3120.0	68.64	\$86.27	\$14.90
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$196.36	\$14.90
Area: (223) Building #800 - Restroom - M													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	3120.0	748.80	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	3120.0	449.28	\$131.21	\$46.05
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$335.60	\$46.05
Area: (224) Building #800 - Room 800 - Main Area													
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$590.41	\$205.59
18	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	1.08	3120.0	3369.60	18	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.65	3120.0	2021.76	\$590.41	\$205.59
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$1,492.39	\$411.18
Area: (225) Building #800 - Room 805 - Main Area													
6	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.36	3120.0	1123.20	6	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.22	3120.0	673.92	\$196.82	\$71.21
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$306.91	\$71.21
Area: (226) Building #800 - Room 805 - Stock Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	3128.4	187.70	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	3128.4	112.62	\$32.10	\$11.54
						1	Control Occupancy Wall Box					\$110.09	\$0.00
												\$142.19	\$11.54
Area: (227) Building #800 - East Boiler Room NXT Room 805													
10	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.60	3120.0	1872.00	10	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.36	3120.0	1123.20	\$328.00	\$96.53
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
												\$639.57	\$96.53
Area: (228) Exterior - Skateboard Park													
6	MH 400W 1L	458.0	2.75	4368.0	12003.26	6	LED Retrofit 118w (400w HID) 5000K Type 5 Global Tech	118.0	0.71	4368.0	3092.54	\$2,553.68	\$1,044.05
						6	Control Photocell Buffered Field Installed					\$416.28	\$0.00

											\$2,969.96	\$1,044.05	
Area: (229) Little League - Field House - Snack Bar Area													
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	1456.0	349.44	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	1456.0	209.66	\$139.45	\$25.67
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	1456.0	349.44	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	1456.0	209.66	\$5.73	\$25.67
4	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.24	1456.0	349.44	4	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.14	1456.0	209.66	\$5.73	\$25.67
16	INC 60A	60.0	0.96	3120.0	2995.20	16	LED Screw-in A19 10w 3000K TCP	10.0	0.16	3120.0	499.20	\$265.03	\$333.06
											\$415.94	\$410.07	
Area: (231) Little League - Field House - Restroom - M													
8	INC 60A	60.0	0.48	3120.0	1497.60	8	LED Screw-in A19 10w 3000K TCP	10.0	0.08	3120.0	249.60	\$132.52	\$166.53
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$106.83	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
											\$443.74	\$166.53	
Area: (232) Little League - Field House - Umpire's Room													
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	1456.0	87.36	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	1456.0	52.42	\$1.40	\$6.42
1	T8-4'-32w-1st Gen-2lamp-EI-RS-NLO	60.0	0.06	1456.0	87.36	1	LED T8 4' 15w (18w DLC) 2L 5000K TCP	36.0	0.04	1456.0	52.42	\$1.40	\$6.42
						1	Control, Wireless, Lutron Wall-Box Switch (5A)					\$107.18	\$0.00
						1	Control Occupancy Ceiling Dual Technology					\$204.39	\$0.00
											\$314.37	\$12.84	

La Sierra Community
 Center
 5325 Engle Road
 Citrus Heights, California
 95608

Appendix B: Material List Summary

* Per Item Cost

Equipment	Quantity	Equipment Cost *	Labor Hrs / Cost *
LED T8 4' 15w (19w DLC) 5000K Green Creative- Green Creative - 97834	106.0	\$0.00	0.12 /\$8.40
LED T8 2L Labor	1306.0	\$0.00	0.12 /\$0.00
Recycle: Fluorescent Lamps 4' or Shorter	2689.0	\$0.70	0 /\$0.00
Recycle: Non-PCB Ballast from 4' or Shorter	1305.0	\$0.00	0 /\$0.00
Control, Wireless, Lutron Wall-Box Switch (5A)- Lutron - PD-5S-DV-WH	151.0	\$66.75	0.5 /\$0.50
Control, Wireless, Lutron Corner Mount Sensor- Lutron - LRF2-OKLB-P-WH	45.0	\$63.75	0.5 /\$0.50
LED Exit Fixture 4w w/Emergency Light Red- TCP - 20784	39.0	\$84.93	0.5 /\$35.00
Control Occupancy Ceiling Dual Technology- Wattstopper - DT-200	88.0	\$169.65	0.3 /\$0.30
LED Screw-in A19 10w 3000K TCP- TCP - LED10A19DOD30K	42.0	\$9.81	0.08 /\$5.60
LED T8 4' 15w (18w DLC) 5000K TCP- TCP - LED4T815IS50K	2160.0	\$10.31	0 /\$0.00
Control Occupancy Wall Box- WattStopper - PW-100	69.0	\$69.44	0.5 /\$0.50
Control, Wireless, Lutron Hallway Sensor- Lutron - LRF2-OHLB-P-WH	13.0	\$63.75	0.5 /\$0.50
LED Screw-in PAR38 17w 3000K 40deg TCP- TCP - LED17P38D30KFL	11.0	\$28.94	0.08 /\$5.60
LED T8 1L Labor	6.0	\$0.00	0.08 /\$5.60
Ballast: T8-2L, IS, NBF- Sylvania - 49383	140.0	\$15.73	0.33 /\$23.10
LED Exit Fixture 4w Red- Maxlite - 85003	23.0	\$27.50	0.5 /\$35.00
Labor_Remove Fixture	8.0	\$0.00	0.33 /\$23.10
LED Retrofit Strips 4ft 2pc 72w 5000K 10800L Linmore- Linmore - LL-URS-4NA-2-50K-72W	32.0	\$147.45	0.33 /\$23.10
LED Screw-in A19 18w 3000K TCP- TCP - LED18A21DOD30K	5.0	\$23.45	0.08 /\$5.60
Control Occupancy Wall Box Dual Switch- WattStopper - PW-200	14.0	\$79.40	0.5 /\$0.50
LED T8 2' 8w (11w DLC) 5000K Green Creative- Green Creative - 8T8/2F/850/DIR 97744	34.0	\$16.81	0 /\$0.00
Reflector Troffer 2x2 2L- Wellmade Reflectors - R304-224T8	16.0	\$16.41	0.08 /\$5.60
LED Retrofit 118w (400w HID) 5000K Type 5 Global Tech- Global Tech - GTR-AR-5498-HO-SV-BR-360S UVBR	6.0	\$308.13	0.75 /\$52.50
Recycle: HID Lamps	6.0	\$2.50	0 /\$0.00
Recycle: Ballast from HID	6.0	\$0.00	0 /\$0.00
Control Photocell Buffered Field Installed- Intermatic - K4221C	6.0	\$31.25	0.33 /\$0.33

11/8/2016

CARMICHAEL RECREATION & PARK DISTRICT
CIP UPDATE
FY 2016-17

<u>Project</u>	<u>Budget</u>	<u>Spent/ Committed</u>	<u>Balance</u>
LSCC Gyms Floors Replacement	147,805	147,805	0
LSCC Sewer Line	104,373	94,254	10,119
LSCC Suite 170 Roof Replacement	89,000	34,570 *	54,430
LSCC John Smith Hall Improvements	50,000	50,000	0
ADA Improvements	30,000	30,000	0
Miscellaneous/Undesignated (park fees)	<u>52,796</u>	<u>0</u>	<u>52,796</u>
	473,974	356,629	117,345
Vet's Hall Playground Surfacing	70,000	32,000	38,000
Jensen Access Trail/Handicap Path	23,000		23,000
Miscellaneous/Undesignated (park fees)	52,797	0	52,797
Miscellaneous/Undesignated through donations	<u>40,000</u>	<u>12,500 **</u>	<u>27,500</u>
	185,797	44,500	141,297
TOTAL	\$659,771		\$258,642

* Project start

**Foundation commitment to the LSCC John Smith Community Hall

**CARMICHAEL RECREATION AND PARK DISTRICT
PARKLAND DEDICATION TRUST & PARK IMPACT FEES**

11/7/2016

Summary

PARKLAND DEDICATION TRUST (IN LIEU FEES)

CURRENT BALANCE: (incl interest earnings)	\$ 369,338.15
COMMITMENTS:	
CP Dog Park Renovation	(23,846.00)
Sutter-Jensen Improvement	(16,784.00)
FY 2015-16 PROJECT EXPENDITURES:	(191,972.00)
TOTAL AVAILABLE AFTER COMMITMENTS:	<u>\$ 136,736.15</u>

PARK IMPACT FEES

CURRENT BALANCE: (incl interest earnings)	\$ 468,533.96
COMMITMENTS:	
CP Pool Demolition/Restoration	(37,613.00)
CP Master Plan	(25,000.00)
CP Dog Park Renovation	(30,154.00)
LSCC Gym Roof	(11,142.00)
County Administration Fees (estimate)	<u>(10,000.00)</u>

TOTAL AVAILABLE AFTER COMMITMENTS: \$ 354,624.96

TOTAL - PARK IMPACT & IN LIEU FEES: \$ 491,361.11

AVAILABLE BALANCE: \$ 491,361.11

BUDGETED USES FOR FY2016-17:

REBUDGETS:

LSCC Sewer	104,373
CP VETs Playground	70,000
Jensen Access Trail/Handicap Path	<u>23,000</u>
	197,373

FY2016-17 PB:

(ADA Imp, LSCC Ste 170 Roof)	119,000
------------------------------	---------

NEW:

LSCC Smith Hall	50,000
Miscellaneous/Undesignated	<u>105,593</u>
	155,593

TOTAL ALLOCATION: \$ 471,966.00

BALANCE: \$ 19,395.11 New Undesignated